

2021 Event Date	Location of Overflow	Duration (Hours)	Volume Estimate (Gallons)	Rainfall Amount (inch)	Cause	Overflow or Release
2/8/2021	9020 Overlook Blvd	0.6	50	N/A	Contractor	Release
3/1/2021	3088 Hillsboro Rd	23.92	394,625	3.06	Wet Weather (3.06 inches of rain)	Overflow
	5403 Williamsburg Rd	12.42	204,875			
	5401 Williamsburg Rd	12.42	204,875			
	Tower Park	8.25	24,750			
3/25/2021	3088 Hillsboro Rd	4.5	74,250	2.32	Wet Weather (2.32 inches of rain)	Overflow
	5403 Williamsburg Rd	3.08	50,875			
	Tower Park	2.08	6,250			
3/27/2021	3089 Hillsboro Rd	59.83	987,250	6.1	Wet Weather (6.10 inches of rain)	Overflow
	5404 Williamsburg Rd	48.33	797,500			
	Tower Park	39.25	117,750			
	1100 Knox Valley Dr	39.25	117,750			
	8207 Concord Rd	39.25	58,875			
	9681 Concord Rd	1	1,500			
	930 Green Hills Blvd	9.67	2,900			
	6430 Murray Ln	4.5	1,350			
	9465 Ashford Pl	9.67	2,900			Release
3/31/2021	3089 Hillsboro Rd	21.17	349,250	1.67	Wet Weather (1.67 inches of rain)	Overflow
	5404 Williamsburg Rd	18.08	298,375			
	Tower Park	14.17	42,500			
6/4/2021	7100 Moores Lane	1	300	N/A	Mechanical	Release
7/8/2021	6332 Murrany Lane	18	1,000	N/A	Pipe Break	Overflow
7/19/2021	1310 Choctaw Trail	2	600	N/A	Grease/Debris	Release
8/6/2021	6220 Murrany Lane	5	1,000	N/A	Pipe Break	Overflow
8/31/2021	3088 Hillsboro Rd	14.83	178,000	3.79	Wet Weather (3.79 inches of rain)	Overflow
9/18/2021	3088 Hillsboro Rd	2.75	33,000	2.44	Wet Weather (2.44 inches of rain)	Overflow
9/20/2021	3088 Hillsboro Rd	24.5	404,250	2.7	Wet Weather (rain)	Overflow
	5403 Williamsburg Rd	13.33	160,000			
	Tower Park	12.08	36,250			
9/24/2021	6220 Murrany Lane	5	1,000	N/A	Pipe Break	Overflow
11/2/2021	409 Wilson Pike	1	50	N/A	Pipe Break	Release