

2022 Event Date	Location of Overflow	Duration (Hours)	Volume Estimate (Gallons)	Rainfall Amount (inch)	Cause	Overflow or Release
1/1/2022	3088 Hillsboro Rd	5.42	32,500	1.81	Wet Weather (1.81 inches of rain)	Overflow
1/9/2022	3088 Hillsboro Rd	12.92	213,125	1.3	Wet Weather (1.30 inches of rain)	Overflow
	5403 Williamsburg Rd	6.42	77,000			
1/19/2022	3088 Hillsboro Rd	18.83	169,500	0.93	Wet Weather (0.93 inches of rain)	Overflow
	5403 Williamsburg Rd	2.42	3,625			
2/4/2022	3088 Hillsboro Rd	9	108,000	2.43	Wet Weather (2.43 inches of rain)	Overflow
2/8/2022	6420 Johnson Chapel Road West	3.5	50	n/a	Contractor	Release
2/18/2022	3088 Hillsboro Rd	4.25	51,000	1.87	Wet Weather (1.87 inches of rain)	Overflow
2/22/2022	3089 Hillsboro Rd	80.17	1,322,750	4.65	Wet Weather (4.65 inches of rain)	Overflow
	5403 Williamsburg Rd	49.17	811,250			
	6219 Belle Rive Drive	33.75	50,625			
	500 Pointer Place	46.17	811,250			
	Tower Park	47.42	569,000			
	8207 Concord Rd	18.75	375,750			
	1100 Knox Valley Dr	18.75	375,750			
	930 Green Hills Blvd	23	6,900			
3/25/2022	701 Davis Drive	70.5	2,000	n/a	Broken Pipe	Overflow
4/13/2022	6430 Murray Lane	1.9	1,000	n/a	Electrical Failure	Overflow
4/14/2022	6418 Johnson Chapel Road West	3.25	75	n/a	Broken Pipe	Release
4/16/2022	8097 Moores Lane	4	500	n/a	Electrical Failure	Overflow
5/5/2022	211 Williamsburg Circle	2.25	200	n/a	Blockage (Debris)	Overflow
5/10/2022	810 Wilson Pike	0.5	50	n/a	Blockage (Debris)	Release
5/12/2022	216 Centerview Drive	1	3,000	n/a	Blockage (Grease)	Overflow
6/17/2022	6402 Fischer Ct	2	500	n/a	Mechanical (Station)	Release
7/26/2022	6402 Fischer Ct	1.5	300	n/a	Mechanical (Station)	Release
8/2/2022	6402 Fischer Ct	1	200	n/a	Mechanical (Station)	Release