

2023 Event Date	Location of Overflow	Duration (Hours)	Volume Estimate (Gallons)	Rainfall Amount (inch)	Cause	Overflow or Release
1/3/2023	5403 Williamsburg Rd		811,250	3.06	Wet Weather	Overflow
	Tower Park		569,000			
	6402 Fischer Ct		6,900			
2/4/2023	8097 Moores Lane		500	n/a	Electrical Failure	Overflow
6/14/2023	8097 Moores Lane		200	n/a	Electrical Switch Failure	Overflow
7/20/2023	5403 Williamsburg Rd		3,000	n/a	Power Outage, station programming fault	Overflow
8/29/2023	8105 Moore's Ln		1,000	n/a	Air Release Valve Failure	Overflow
9/18/2023	930 Green Hill Blvd (Chenoweth SPS)		2,400	n/a	Bypass Pump breakdown	Overflow
11/14/2023	6409 Eastbourne Drive		100	n/a	Contractor Damage	Release