

2024 Event Date	Location of Overflow	Duration (Hours)	Volume Estimate (Gallons)	Rainfall Amount (inch)	Cause	Overflow or Release
4/1/2024	7094 Willowick Dr	4	300	N/A	Air release valve failure	Overflow
9/26/2024	5403 Williamsburg Rd	4	48,000	5.15	Wet weather	Overflow
	960 Heritage Way	4	48,000	5.15	Wet weather	
11/11/2024	722 Wilson Pike	12	100	N/A	Contractor struck low-press. force main	Release
12/11/2024	12 Carmel Ln	19	5,700	N/A	Fats/oil/grease blockage	Release